



5 Star Extinguisher Services

6/159 Chifley Street Wetherill park NSW 2164

ABN: 55 209 172 495

P.O. Box 345 Toongabbie NSW 2146

Telephone: (02) 9609 7420 **Mobile:** 0413 283 150 **Facsimile:** (02) 9609 6303

INSPECTION PROCEDURES FIRE INDICATOR PANELS

Reference: AS/NZS 1670

Inspection Checks Include:

1. External Damage
2. External Corrosion
3. Batteries
4. Alarm Panel Test Dependant Upon System
5. Complete Log Book

INSPECTIONS ARE PERFORMED ON A MONTHLY BASIS.