



5 Star Extinguisher Services

6/159 Chifley Street Wetherill Park NSW 2164

ABN: 55 209 172 495

P.O. Box 345 Toongabbie NSW 2146

Telephone: (02) 9609 7420 **Mobile:** 0413 283 150 **Facsimile:** (02) 9609 6303

INSPECTION PROCEDURES FIRE HYDRANTS

Reference: **AS 2419-1**
AS/NZS 1851-4

Inspection Checks Include:

1. SIX MONTHLY INSPECTION:

- ✓ Instructions for operation are clearly legible.
- ✓ That there is no leakage of water.
- ✓ That there is no damage or corrosion to stem or valve.
- ✓ Gate valve is in place and not corroded.
- ✓ Hydrant caps are in place.
- ✓ Pathways are clear to and from hydrant

2. ANNUAL INSPECTION:

- ✓ As per SIX MONTHLY INSPECTION however flow test to be conducted with a flow meter test gauge.

3. LOCATION SIGNS AND PATHWAYS CLEARLY VISIBLE.