



## 5 Star Extinguisher Services

6/159 Chifley Street Wetherill Park NSW 2164

ABN: 55 209 172 495

P.O. Box 345 Toongabbie NSW 2146

**Telephone:** (02) 9609 7420 **Mobile:** 0413 283 150 **Facsimile:** (02) 9609 6303

# INSPECTION PROCEDURES PORTABLE FIRE EXTINGUISHERS

**Reference: AS 2444**  
**AS/NZS 1851-1**

### Inspection Checks Include:

1. External Damage
2. External Corrosion
3. Discharge Nozzle
4. Outlet Hose & Nozzle
5. Contents
6. Pressure Indicators
7. Operating Head
8. Actuating Device And Internal Components
9. Seals And Gaskets
10. Label
11. Leak Detection
12. Location
13. Identification Signs
14. Location Signs
15. Maintenance Tags
16. Anti Tamper Seals
17. Pressure Test